



STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH

June 20, 2002

Mr. Paul Naslund,
Engineering Manager, Dispensing Systems
DEMA International
10020 Big Bend Blvd.
St. Louis, MO 63122

Dear Mr. Naslund:

I have reviewed the information that you have provided to me regarding the DEMA 16-30 Reaction Gap Assembly backflow preventer that is included in chemical dispensing equipment.

The documentation you provided indicates this device meets ASSE Standard 1055.

Standard 1055 is for Chemical Dispensing Systems and includes requirements for backflow prevention as well as testing under back siphonage conditions.

Based on my review, dispensers containing the DEMA 16-30 meet the Public Health Code requirements.

Sincerely,

Robert W. Rivard, P.E.
Supervising Sanitary Engineer
Water Supplies Section

INTENT TO WITHDRAW FROM THE MARKET
FOR THE STATE OF CONNECTICUT
ELECTRONIC COPY
REVISIONS TO THE
DATE OF THE



Phone: (860) 509-7333
Telephone Device for the Deaf (860) 509-7191
410 Capitol Avenue - MS # 51WAT
P.O. Box 340308 Hartford, CT 06134
An Equal Opportunity Employer